

Certificate

Registration No.: PV 60025422

Page 1

Report No.: 15031989.001

License Holder:

Jiangsu Green Power PV Co., Ltd.

1 Longmen Road, New District
213161 Wujin, Changzhou
China

Product:

PV Module

Type: GPM205-A-96, GPM210-A-96, GPM215-A-96
GPM220-A-96, GPM225-A-96, GPM230-A-96
GPM235-A-96, GPM240-A-96, GPM245-A-96
GPM250-A-96 (with 96 cells)

GPM160-A-72, GPM165-A-72, GPM170-A-72
GPM175-A-72, GPM180-A-72, GPM185-A-72
GPM190-A-72 (with 72 cells)

Manufacturing Plant:

Wuxi Guofei Green Energy Source Co., Ltd.
Zhenfa 7 Road, Shuofang Industrial Park
214142, Wuxi
China

Basis:

IEC 61730-1:2004
IEC 61730-2:2004
EN 61730-1:2007
EN 61730-2:2007
"Photovoltaic (PV) module safety
qualification"

Factory Inspection
To document the consistent quality of
the product factory inspections are
performed periodically.



- Qualified, IEC 61215
- Safety tested,
IEC 61730
- Periodic Inspection

Remarks:

- IEC EN 61730 consists of part 1 (Requirements for construction) and part 2 (Requirements for testing).
- The above listed PV modules fulfil the requirements of Application Class A (Safety Class II). They may be used in PV plants at a maximum system voltage (Voc at STC) of up to **1000 VDC**.
- The fire test (IEC 61730-2 / MST 23) was not performed.
- The details of the factory inspection are documented in report no. 153088558.

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

The certificate is valid until 23 May 2014.



Cologne, 23 May 2009

Dipl.-Ing. M. Adrian